



---

## Declaration of Conformity

---

*We* **Broyce Control Ltd**

*Of* Pool Street  
Wolverhampton  
West Midlands  
England  
WV2 4HN

Declare under our sole responsibility that the products:

**Liquid Level Relays:** (8-pin) B8HLD, B8LCE, B8LCF, B8LDE, B8LDF, B8LCR  
(11-pin) B1LCE, B1LCF, B1LDE, B1LDF, B1LDF/Z104, B1LCR

to which this Declaration relates are in conformity with the following standards:

<b>IEC 61010-1</b>	Dual polarity electrical mains transient @ 4kV
<b>BS EN 61000-4-2</b>	Electrostatic discharge test @ 8kV (Class 3)
<b>BS EN 61000-4-3</b>	Radio Frequency Immunity test @ 3V/m (Level 2) 80 – 1000MHz
<b>BS EN 61000-4-4</b>	Transient burst @ 2kV 5KHz Level 3
<b>EN 55 022</b>	Conductive emissions 9KHz – 30MHz
<b>EN 55 022</b>	Radiative emissions 9KHz – 1000MHz

following the provisions of EMC Directive 89/336/EEC:

---

Signed by and on behalf of **Broyce Control Ltd**

*Signature:* \_\_\_\_\_  
(David Gough)

*Position:* General Manager

*Date:* 20<sup>th</sup> August 2011