Declaration of conformity

We BROYCE CONTROL LTD
Of Pool Street
Wolverhampton
England
WV2 4HN

Declare under our sole responsibility that the products

45PUVR, 45PUVR-4W, 45POVR, 45POVR-4W, 45UVR, 45OVR, 45PSR, 45UFR, 45OFR, 45UCR, 45OCR

to which this Declaration relates are in conformity with the following standard

IEC 1010-1	Dual polarity electrical mains transient @ 4KV
IEC 801 part 4	Transient burst @2KV 5KHz level 3
IEC 801 part 2	Electrostatic contact discharge test @ 8KV (Class 3)
IEC 801 part 3	Radio Frequency Immunity test @ 3V/m (level 2)
EN 60 555 part 2	Conductive emissions 0 – 2KHz
EN 55 022	Conductive emissions 9KHz – 30MHz
EN 55 022	Radiative emissions 9KHz – 1000Mz

following the provisions of EMC Directive 89/336/EEC

Signed by and on behalf of **Broyce Control Ltd**:

Date: 4/6/2001

Name: David Gough

Position: General Manager.